



CITY OF FRISCO PURCHASING DIVISION

September 23, 2011

Addendum #1

QUESTIONS & ANSWERS

Bid#1109-067

BRUSHPILES - Can we “chip in place” as long as we chip into the trees and not the fairways? – **Yes, you can chip the debris and disperse it into the natural area.**

CONCRETE FOR TEE BOXES AND PIERS – Do you have any details for the steel? – **There is no detail for the steel for the concrete tee boxes. However, we do require #4 rebar, 18” OC.**

TESTING – Is Contractor responsible for paying for testing? – **No. We will only require an approved TXDOT batch plant report.**

Vendors who may have already submitted a bid and feel this addendum may change their bid price, may pick up their bid, and return it by the closing date. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted. Acknowledge receipt of this addendum by initialing in the appropriate space on the bid document.

Sincerely,

Jean Stelatella, CPIM, CPPB
Buyer
City of Frisco